



Greater Noida Industrial Development Authority

Plot No.-01, Sector- K.P.-4, Greater Noida City, District-Gautam Budh Nagar (U.P.)

website: www.greaternoidaauthority.in email id: authority@gnida.in


Letter Ref. No. : JAL/2024/ 456

Date : 10/4/24

SAFE DRINKING WATER CERTIFICATE

It is certified that drinking water as per test report (attached) from SHREE RAM TESTING LABORATORIES, Greater Noida in premises of **Seth Anandram Jaipuria School, Plot No-02A, Sector K.P.-05, Greater Noida** was Submitted by Principal of Seth Anandram Jaipuria School found satisfactory. You are requested to ensure to above the condition throughout the norms by the Central/State/UP Govt.


This certificate is valid for one year from date of issue.


Senior Manager (JAL)

To,

The Principal
Seth Anandram Jaipuria School,
Plot No-02A, Sector K.P.-05,
Greater Noida.
G.B. Nagar (U.P.)


Manager
Seth Anandram Jaipuria School
Greater Noida West


PRINCIPAL
Seth Anandram Jaipuria School
Greater Noida West



Complete Analytical Solution
ISO 14001 : 2015 & ISO 9001 : 2015 Certified

SHREE RAM TESTING LABORATORIES

ISO 14001 : 2015 & ISO 9001 : 2015 Approved Laboratory

Lab: A-2/103, Site-V, UPSIDC Industrial Area, Kasna, Greater Noida-20

H.O. 223, 2nd Floor, Living Style Mall, Jasola, New Delhi-110

Mob: 9953984801, 9717160780, 9999024801, E-mail: stl.noida@gmail

E-mail: info@shreeramlab.com, shreeramlab@yahoo.com, Website: www.shreeramlab.com

TEST REPORT

Issued to : M/S Seth Anandram Jaipura School Knowledge Park -5 Plot No- 2A Greater Noida	Report No.	W-010424-01
	Report date:	05/04/2024
	Sample Received:	01/04/2024
	Analysis date:	01/04/2024 to 05/04/2024
	Sampled By:	customer

Sample Description: Drinking Water RO

P- 1/1

Received Sample in Sealed and marked Plastic Bottle

RESULT

Drinking Water-Essential Tests as per IS 10500:2012

S.No.	Parameters (Units)	Test Method	Results	Requirement as per IS: 10500-2012
1.	Odour	IS:3025(P-5) 2018	Unobjectionable	Unobjectionable
2.	Taste	IS:3025(P-8) 1984 (RA- 2017)	Agreeable	Agreeable
3.	Colour (Hazen)	IS:3025(P-4) 2021	<1.0	5 max
4.	Turbidity (NTU)	IS:3025(P-10) 1984 (RA- 2017)	Nil	1 max
5.	pH value (at 25 °C)	IS:3025(P-11) 1983 (RA- 2017)	7.12	6.5 to 8.5
6.	Total Dissolved solids (mg/l)	IS:3025(P-16) 1984 (RA- 2017)	92	500 max
7.	Total Hardness (as CaCO ₃) (mg/l)	IS 3025 P-21:2009 (RA- 2019)	62	200 max
8.	Chloride (as Cl) (mg/l)	IS:3025(P-32) 1988 (RA- 2019)	28.04	250 max
9.	Iron (as Fe) (mg/l)	IS:3025(P-53) 2003 (RA- 2019)	0.01	0.3 max
10.	Residual Free Chlorine(mg/l)	IS:3025(P-26) 2021	Nil	0.20 max
11.	Fluoride (as F) (mg/l)	APHA 4500 (D)	0.011	1.0 max
12.	Total Alkalinity (as CaCO ₃), (mg/l)	IS:3025(P-23)- 1986 (RA- 2019)	72.4	200 max
13.	Magnesium (as Mg), (mg/l)	IS:3025(P-46)- 1994 (RA- 2019)	5.42	30 max
14.	Aluminum (as Al) (mg/l)	IS:3025(P-55)- 2003 (RA- 2019)	Not Detected	0.03 max
15.	Zinc (as Zn), (mg/l)	IS:3025(P-49)- 1994 (RA- 2019)	0.01	5 max
16.	Lead (as Pb), (mg/l)	IS:3025(P-47)- 1994 (RA- 2019)	Not Detected	0.01 max
17.	Mercury (as Hg), (mg/l)	IS:3025(P-48)- 1994 (RA- 2019)	Not Detected	0.001 max
18.	Total Arsenic (as As), (mg/l)	IS:3025(P-37)- 1988 (RA- 2019)	Not Detected	0.01 max
19.	MICROBIOLOGICAL PARAMETERS			
i	Coliform (cfu/100ml)	IS 1622:1981 (RA- 2019)	Absent	0 max
ii	E. Coli (cfu/100ml)	IS 1622:1981 (RA-2019)	Absent	0 max

Remark: The Tested Parameters meet as per BIS specification.

END OF REPORT **PRINCIPAL**

Seth Anandram Jaipuria School
Greater Noida West

TESTED BY
[Signature]

Manager
Seth Anandram Jaipuria School
Greater Noida West

